


NOTES:
BASIN EMBANKMENT CONSTRUCTION:

1. EMBANKMENT MATERIAL SPECIFICATIONS: EMBANKMENT CORE AND CUT OFF TRENCH MATERIAL SHALL BE MATERIAL CONFORMING TO UNIFIED SOIL CLASSIFICATION GC, SC, CH, OR CL WITH AT LEAST 30% PASSING #200 SIEVE. CORE AND CUT OFF TRENCH MATERIAL SHALL BE STOCKPILED SEPARATELY FROM OUTER SHELL MATERIAL. MATERIAL SHALL BE FREE OF ROOTS, STUMPS, WOOD, RUBBISH, STONES GREATER THAN 6-INCHES, FROZEN OR OTHER OBJECTIONABLE MATERIALS. STOCKPILED MATERIAL SHALL BE COVERED AND PROTECTED FROM WATER, TRAFFIC AND OTHER DELETERIOUS SUBSTANCES OR PROCESSES.

2. EMBANKMENT COMPACTION: EMBANKMENT FILL SHALL BE PLACED IN 12-INCH LIFTS MAXIMUM AND COMPACTED. THE MINIMUM REQUIRED DENSITY SHALL NOT BE LESS THAN 95% OF MAXIMUM DRY DENSITY WITH A MOISTURE CONTENT WITHIN 2% OF OPTIMUM. ALL COMPACTION TO BE DETERMINED BY AASHTO METHOD 99 STANDARD PROCTOR.

3. EMBANKMENT CORE DIMENSIONS: THE CORE SHALL BE PARALLEL TO THE CENTERLINE OF THE EMBANKMENT AS SHOWN ON THE PLANS. THE TOP WIDTH OF THE CORE SHALL BE A MINIMUM OF FOUR FEET. THE HEIGHT SHALL EXTEND UP TO AT LEAST THE 10 YEAR WATER ELEVATION OR AS SHOWN ON THE PLANS. THE SIDE SLOPES SHALL BE 1 TO 1 OR FLATTER. THE CORE SHALL BE COMPACTED WITH CONSTRUCTION COMPACTION EQUIPMENT, ROLLERS, OR TAMPS TO ASSURE MAXIMUM DENSITY AND MINIMUM PERMEABILITY. THE CORE SHALL BE CONSTRUCTED/PLACED CONCURRENTLY WITH THE OUTER SHELL OF THE EMBANKMENT.


4. EMBANKMENT SURFACE: A 4-INCH LAYER OF TOPSOIL SHALL BE PLACED ON ENTIRE SURFACE AREA OF THE EMBANKMENT. GOOD GRASSSED COVER SHALL BE ESTABLISHED BY SEEDING, LIMING, FERTILIZING, MULCHING, ETC. IN ACCORDANCE WITH NEW YORK STATE STANDARDS AND SPECIFICATIONS FOR SOIL EROSION AND SEDIMENT CONTROL. EMBANKMENT SHALL BE KEPT FREE OF WOODY PLANT GROWTH AND TREES.



Design CS

Infiltration Basin Details	
Bottom Length (ft)	150
Bottom Width (ft)	10
Bottom Surface Area (sqft)	1490
Floor of Practice (ft)	733.000000
Berm El. (ft)	738.000000
Emergency Overflow El. (ft)	737.50

REVISIONS <table border="1"> <tr> <th>NO.</th> <th>DATE</th> <th>DESCRIPTION</th> </tr> <tr> <td>1</td> <td>03-06-2012</td> <td>ISSUED FOR PERMITS</td> </tr> </table>		NO.	DATE	DESCRIPTION	1	03-06-2012	ISSUED FOR PERMITS
NO.	DATE	DESCRIPTION					
1	03-06-2012	ISSUED FOR PERMITS					
STORMWATER DETAILS WATER USE ADDITION WATER IN ALTERNATIVE REMEDIATED WASTEWATER APPROVED UNDER NEW YORK STATE ENVIRONMENTAL CONSENT DECISION 400' BROADWAY SCARSDALE, NEW YORK 11580 COUNTY OF WESTCHESTER							
TIMOTHY C. BUHL, P.E. SEATTLE, WA 98101 TEL: 206.462.4000							
DATE: 03-06-2012 SHEET NO: 000000 PROJECT: E.D. JOB: + SHEET: ST-2							




MICHAEL J. PALMER ARCHITECT
 8020 SOUTH STREETS ROAD
 AUBURN, NEW YORK 13021
 PHONE: 315-255-1010
 EMAIL: MPALMER@OUTLOOK.COM

WAREHOUSE ADDITION
 FOR: HABA TOYS
 4407 JORDAN ROAD
 NEW YORK
 SKANEATELES,

PARTIAL
 FLOOR PLAN
 "A"

A-2
 OF 6

PROGRESS
PRINT



1 FLOOR PLAN
A-B ROOM 1/8" = 1'-0"


LEGEND	
	NEW WALL
	EXISTING WALL OTHER WALL
	NEW DOOR
	EXISTING DOOR

WAREHOUSE ADDITION
FOR: HABA TOYS 4407 JORDAN ROAD
SKANEATELEGS, NEW YORK

DATE: 4/20/22
DRAWING NO.: A-3
REV: 0

MICHAEL J. PALMISTE ARCHITECT
6020 SOUTH HYPERST ROAD
AUBURN, NEW YORK 13021
PHONE: 315-255-1010
EMAIL: MPALMISTE@OUTLOOK.COM

PROGRESS
PRINT



1 SECOND FLOOR PLAN
1/8" = 1'-0"


LEGEND	
	WALL
	DOOR
	DOOR SWING
	DOOR SWING
	DOOR SWING

MICHAEL J. PALMISTE ARCHITECT
6020 SOUTH EVERETT ROAD
AUBURN, NEW YORK 13021
PHONE: 315-250-1010
EMAIL: MPALMISTE@OUTLOOK.COM


WAREHOUSE ADDITION
FOR: HABA TOYS
4407 JORDAN ROAD
NEW YORK
SKANEATELES,

SECOND FLOOR PLAN
& DETAILS


DATE: 11/11/2021
DRAWING NO.:
A-4
BY: S



1 WEST ELEVATION
A-B SCALE: 1/8" = 1'-0"



2 EAST ELEVATION
A-B SCALE: 1/8" = 1'-0"



3 NORTH ELEVATION
A-B SCALE: 1/8" = 1'-0"

PROGRESS PRINT

MICHAEL J. PALMISTE ARCHITECT
6020 SOUTH STREET ROAD
AUBURN, NEW YORK 13021
PHONE: 315-255-1010
EMAIL: MPALMISTE@OUTLOOK.COM

WAREHOUSE ADDITION
FOR: HABA TOYS
4407 JORDAN ROAD
NEW YORK
SKANEATELEGS

PLATING TITLE:
ELEVATIONS

MARCH 24, 2022
REVISION NO.
A-5
BY: S